

Certificate of constancy of performance,

0832-CPR-F1304

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

L-MC-SG Wireless Libra Addressable Multicriteria Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

Argus Security S.r.l.

**Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy**

and produced in the manufacturing plant(s)

Argus Security S.r.l.

**Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-7:2000 +A1:2002 +A2:2006 Smoke Detectors

EN 54-5:2000 +A1:2002 Heat Detectors

EN 54-25:2008 Components Using Radio Links

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 12 December 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 12 December 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F1304

Notes:

1. Meets the requirements of EN 54-5 for Class A1R
2. Meets the requirements of EN 54-7 at the following sensitivity settings:
Level 1 - High
Level 2 - Normal
Level 3 - Low
3. The device must be used with the following battery type only:
CR123A (3 Vdc) - Primary and Secondary Battery

Base:

WAB100 – Wireless Adaptor Base



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 12 December 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.